

City of Big Bear Lake



July 14, 2017

ADDENDUM NO. 1

TO

**CITY OF BIG BEAR LAKE,
STATE OF CALIFORNIA**

STREETS 2017/2018 FISCAL YEAR

To all Invited Bidders:

Please note the following changes and responses to written questions:

1. Please note that bid item #10 "Placement of cape seal" shall be done in accordance with the "Greenbook" 2015 Edition Standard Specifications section 302-2. Specifically, the cape seal shall include a "medium" Polymer Modified Emulsified Asphalt at a minimum application rate of 0.33 gal/yd² (per table 302-2.6.2) and a "medium" 3/8 "chip" layer at a minimum application rate of 25 lbs/yd² (per table 302-2.6.4.2). Reuse of swept chips shall not be permitted.
2. Please note that bid item #11 "Type II slurry seal" shall be done in accordance with the "Greenbook" 2015 Edition Standard Specifications section 302-4 and table 302-4.6.4.1.
3. Please note that bid items #10 and #11 shall include the full cost of crack sealing all cracks in excess of 1/4 inch in width prior to placing product on the surface.
4. Please note on item #13 "sub grade soil removal", that pulverized asphalt material is intended to stay on site to be reused as compacted base material. Any subgrade removals that are required to maintain existing grades shall be taken from the native subgrades below the pulverized asphalt layer.

Bidders' attention is directed to Contract Documents, specifically acknowledgement of receipt of addenda, which must be dated and returned in the Bid. Written questions regarding this bid should be directed to Andrew Simmons at asimmons@citybigbearlake.com. All written question must be received no later than 24 hours before bid opening.

THIS ADDENDUM NO. 1 HAS BEEN PREPARED BY

A handwritten signature in blue ink, appearing to read "Andrew R. Simmons", is written over a horizontal line.

Andrew R. Simmons, P.E.
Acting City Engineer